



**CITY OF EAST PROVIDENCE
DEPARTMENT OF PUBLIC WORKS
REQUEST FOR PROPOSALS
EP 20/21-12
BID OPENING TUESDAY, MARCH 30, 2021 AT 11AM
GRASSY PLAINS PARK TENNIS COURT FENCE INSTALLATION
ESTRELL DRIVE**

**ADDENDUM NO. 1
ISSUED 3/23/2021**

- 1) Revised specifications section 02711 Vinyl Clad Chain Link Fence, see attachment.
- 2) Revised Details (2 sheets)
- 3) A bid bond is not required.
- 4) Mesh size will be 2-inch diamond.
- 5) 40 weight pipe (SS-40) is acceptable.
- 6) Fence post concrete footings will be brought flush with top of asphalt pavement, no patching is required.