

ROBERTO L. DASILVA
MAYOR



JESSICA LAMPREY
PROCUREMENT SPECIALIST

**CITY OF EAST PROVIDENCE
PURCHASING DIVISION
145 TAUNTON AVENUE
EAST PROVIDENCE, RI 02914
401-435-7500 EXT. 11270**

To: All Prospective Bidders

From: Jessica Lamprey, Procurement Specialist

Date: Wednesday, July 16, 2025

Re: RFP EP24/25-019 Third Party Testing Services

Please be advised that the following information comprises Addendum #1.

Question: Is the Troxler E-Gauge non nuke method ASTM D8167 an approved equivalent for soils compaction and moisture content testing.

Answer: Our civil engineering consultant indicated that ASTM D8167 is not an approved equivalent. Compaction testing shall be in accordance with ASTM D1556, ASTM D2922, and ASTM D2937, as applicable per our specification.

Thank you for your interest in this project.