

City of East Providence  
Department of Public Works – Engineering Division  
145 Taunton Avenue, East Providence RI 02914

Booth Avenue Slope Stabilization  
0 Booth Avenue  
RFP EP23/24-33

Addendum No. 2  
August 13<sup>th</sup>, 2024

TO ALL CONTRACTORS ESTIMATING:

Bidders are hereby informed that plans and specifications for the above mentioned contract are modified, corrected, and/or supplemented as follows and Addendum No.2 becomes part of the Contract Documents and consists of Item 2.1 through 2.10.

**QUESTIONS AND ANSWERS**

**2.1 Q: “What are the dimensions for the proposed granite curb? The plans and specifications refer to RIDOT Standard 7.6.0 and Standard Specification Section 906, but no dimensions are specified for the proposed granite curb for this project.”**

A: See detail on Sheet C-6

**2.2 Q: “Can you please provide a copy of the applicable state prevailing wage determinations? The specifications state they are included in the supplementary conditions, but we cannot find them in the bid documents.”**

A: See Attachment 1 of this Addendum

**2.3 Q: “Regarding the final design of the RSS, can there be an allowance item added to the bid form for contingencies associated with construction of the final RSS design, or can it be clarified that Item 11 – Allowance for Unforeseen Conditions can be used for this purpose? Currently, the only design contractors can use to estimate project costs is the preliminary design of the RSS that is included in the construction drawings. The final design of the RSS won’t be available until the project is awarded, contracted, and the awarding contractor engages their engineer for design services. As such, we cannot account for any additional costs that may be associated with the final RSS design. We can only include costs for the design itself.”**

A: It is the intent of Item 11 to account for contingencies associated with the construction of the final RSS design.

**2.4 Q: “Will any over excavation of unsuitable soils and associated disposal be covered under Item 11 – Allowance for Unforeseen Conditions?”**

A: Correct

**2.5 Q: “One of the notes for the rip rap sill detail on drawing C-5 states “Excavate as directed by the engineer to a depth where soils exhibit bearing capacity to support concrete habitat blocks”. This is the only mention of “concrete habitat blocks”. Are “concrete habitat blocks” referring to the rip rap sills, or are they a separate product/feature? If they are a separate product/feature, please provide details, specifications, etc., for the habitat blocks.”**

A: The note is referring to the rip rap sill, concrete habitat blocks are not a part of this project.

**2.6 Q: “Can a detail and recommended manufacturer be provided for the park benches?”**

A: See Attachment No. 2, Revised Drawing Sheet C-6

**2.7 Q: “Does the downed/dead wood in the water need to be removed and disposed of?”**

A: Only debris directly conflicting with project are required to be removed.

**2.8 Q: “Can you provide specifications and a recommended manufacturer for the MSE geotextile to be used for the RSS?”**

A: The RSS depicted on the plans was developed with Tensar Sierra Slope components, final RSS products are the responsibility of the final slope designer.

## **SPECIFICATIONS**

**2.9 ADD** Attachment No. 1, Addendum No. 2 to Specification Section SC-32 – Wage Rates

## **DRAWINGS**

**2.10 REMOVE** Drawing Sheet C-6 and **REPLACE** with Drawing Sheet C-6 Revision 1

**Addendum No. 2**  
**Attachment 1 – Rhode Island Wage Rates**

"General Decision Number: RI20240001 07/12/2024

Superseded General Decision Number: RI20230001

State: Rhode Island

Construction Types: Building, Heavy (Heavy and Marine) and Highway

Counties: Rhode Island Statewide.

BUILDING CONSTRUCTION PROJECTS (does not include residential construction consisting of single family homes and apartments up to and including 4 stories) HEAVY, HIGHWAY AND MARINE CONSTRUCTION PROJECTS

Note: Contracts subject to the Davis-Bacon Act are generally required to pay at least the applicable minimum wage rate required under Executive Order 14026 or Executive Order 13658. Please note that these Executive Orders apply to covered contracts entered into by the federal government that are subject to the Davis-Bacon Act itself, but do not apply to contracts subject only to the Davis-Bacon Related Acts, including those set forth at 29 CFR 5.1(a)(1).

\_\_\_\_\_ | If the contract is entered |. Executive Order 14026 | |into on or after January 30, | generally applies to the | |2022, or the contract is | contract. | |renewed or extended (e.g., an |. The contractor must pay | |option is exercised) on or | all covered workers at | |after January 30, 2022: | least \$17.20 per hour (or | | the applicable wage rate | | listed on this wage | | determination, if it is | | higher) for all hours | | spent performing on the | | contract in 2024. | | \_\_\_\_\_ |

\_\_\_\_\_ | |If the contract was awarded on|. Executive Order 13658 | |or between January 1, 2015 and| generally applies to the | |January 29, 2022, and the | contract. | |contract is not renewed or |. The contractor must pay all| |extended on or after January | covered workers at least | |30, 2022: | \$12.90 per hour (or the | | applicable wage rate listed | | on this wage determination, | | if it is higher) for all | | hours spent performing on | | that contract in 2024. | | \_\_\_\_\_ |

The applicable Executive Order minimum wage rate will be adjusted annually. If this contract is covered by one of the Executive Orders and a classification considered necessary for performance of work on the contract does not appear on this wage determination, the contractor must still submit a conformance request.

Additional information on contractor requirements and worker protections

under the Executive Orders is available at <http://www.dol.gov/whd/govcontracts>.

Modification Number Publication Date 0 01/05/2024

- 1 01/12/2024
- 2 02/23/2024
- 3 03/08/2024
- 4 03/22/2024
- 5 04/05/2024
- 6 05/24/2024
- 7 05/31/2024
- 8 06/14/2024
- 9 06/21/2024
- 10 07/05/2024
- 11 07/12/2024

ASBE0006-006 09/01/2023

Rates Fringes

HAZARDOUS MATERIAL HANDLER

(Includes preparation, wetting, stripping, removal scrapping, vacuuming, bagging & disposing of all insulation materials, whether they contain asbestos or not, from mechanical systems).....\$ 48.15 34.84 -----

ASBE0006-008 09/01/2023

Rates Fringes

Asbestos Worker/Insulator

Includes application of all insulating materials, protective coverings, coatings & finishes to all types of mechanical systems.\$ 48.15 34.84 -----

BOIL0029-001 01/01/2021

Rates Fringes

BOILERMAKER.....\$ 45.87 29.02 -----

BRR0003-001 06/01/2022

Rates Fringes

Bricklayer, Stonemason,

Pointer, Caulker & Cleaner.....\$ 46.86 29.14 -----

BRR0003-002 09/01/2022

Rates Fringes

Marble Setter, Terrazzo

Worker & Tile Setter.....\$ 46.54 30.34 -----  
----- BRRIO003-003 09/01/2022

Rates Fringes

Marble, Tile & Terrazzo Finisher.....\$ 38.78 29.61 -----  
----- \* CARP0330-001  
06/03/2024

Rates Fringes

CARPENTER (Includes Soft  
Floor Layer).....\$ 45.13 30.25  
Diver Tender.....\$ 44.88 30.25  
DIVER.....\$ 57.03 30.25  
Piledriver.....\$ 41.53 29.35  
WELDER.....\$ 44.88 30.25

FOOTNOTES:

When not diving or tending the diver, the diver and diver tender shall receive the piledriver rate. Diver tenders shall receive \$1.00 per hour above the pile driver rate when tending the diver.

Work on free-standing stacks, concrete silos & public utility electrical power houses, which are over 35 ft. in height when constructed: \$.50 per hour additional.

Work on exterior concrete shear wall gang forms, 45 ft. or more above ground elevation or on setback: \$.50 per hour additional.

The designated piledriver, known as the "monkey": \$1.00 per hour additional.

----- CARP1121-  
002 01/02/2023

Rates Fringes

MILLWRIGHT.....\$ 41.54 30.73 -----  
----- \* ELEC0099-002 06/01/2024

Rates Fringes

ELECTRICIAN.....\$ 39.09 5.59%+15.64 Teledata System  
Installer.....\$ 39.09 11.02%+15.31

FOOTNOTES:

Work of a hazardous nature, or where the work height is 30 ft. or more from the floor, except when working OSHA-approved lifts: 20% per hour additional.

Work in tunnels below ground level in combined sewer outfall: 20% per hour additional.

----- ELEV0039-  
001 01/01/2024  
Rates Fringes

ELEVATOR MECHANIC.....\$ 61.88 37.885+a+b

FOOTNOTES:

a. PAID HOLIDAYS: New Years Day; Memorial Day; Independence Day; Labor Day; Veterans' Day; Thanksgiving Day; the Friday after Thanksgiving Day; and Christmas Day.

b. Employer contributes 8% basic hourly rate for 5 years or more of service of 6% basic hourly rate for 6 months to 5 years of service as vacation pay credit.

----- ENGI0057-  
001 06/01/2024  
Rates Fringes

Operating Engineer: (power plants, sewer treatment plants, pumping stations, tunnels, caissons, piers, docks, bridges, wind turbines, subterranean & other marine and heavy construction work)

GROUP 1.....	\$ 48.05	29.90	
GROUP 10.....	\$ 41.75	29.90	
GROUP 2.....	\$ 46.05	29.90	GROUP 3.....\$
41.67	29.90		
GROUP 4.....	\$ 38.82	29.90	
GROUP 5.....	\$ 45.10	29.90	
GROUP 6.....	\$ 35.90	29.90	
GROUP 7.....	\$ 29.90	29.90	
GROUP 8.....	\$ 29.90	29.90	
GROUP 9.....	\$ 41.75	29.90	

a. BOOM LENGTHS, INCLUDING JIBS:

- 150 feet and over + \$ 2.00
- 180 feet and over + \$ 3.00
- 210 feet and over + \$ 4.00
- 240 feet and over + \$ 5.00
- 270 feet and over + \$ 7.00
- 300 feet and over + \$ 8.00
- 350 feet and over + \$ 9.00
- 400 feet and over + \$10.00

a. PAID HOLIDAYS:

New Year's Day, President's Day, Memorial Day, July Fourth, Victory Day, Labor Day, Columbus Day, Veterans Day, Thanksgiving Day, Christmas Day. a: Any employee who works 3 days in the week in which a holiday falls shall be paid for the holiday.

a. FOOTNOTES:

Hazmat work: \$2.00 per hour additional. Tunnel/Shaft work: \$5.00 per hour additional.

POWER EQUIPMENT OPERATORS CLASSIFICATIONS

GROUP 1: Cranes, lighters, boom trucks and derricks

GROUP 2: Digging machine, Ross Carrier, locomotive, hoist, elevator, bidwell-type machine, shot & water blasting machine, paver, spreader, graders, front end loader (3 yds. and over), vibratory hammer & vacuum truck, roadheaders, forklifts, economobile type equipment, tunnel boring machines, concrete pump and on site concrete plants.

GROUP 3: Oilers on cranes.

GROUP 4: Oiler on crawler backhoe.

GROUP 5: Bulldozer, bobcats, skid steer loader, tractor, scraper, combination loader backhoe, roller, front end loader (less than 3 yds.), street and mobile-powered sweeper (3-yd. capacity), 8-ft. sweeper minimum 65 HP).

GROUP 6: Well-point installation crew.

GROUP 7: Utility Engineers and Signal Persons

GROUP 8: Heater, concrete mixer, stone crusher, welding machine, generator and light plant, gas and electric driven pump and air compressor.

GROUP 9: Boat & tug operator.

----- \* ENGI0057-  
002 05/01/2024

Rates Fringes

Power Equipment Operator  
(highway construction projects; water and sewerline projects which are incidental to highway construction projects; and bridge projects that do not span water)

GROUP 1.....\$ 41.95 29.75



GROUP 2.....	\$ 39.95	29.75	
GROUP 3.....	\$ 35.23	29.75	
GROUP 4.....	\$ 38.93	29.75	
GROUP 5.....	\$ 38.93	29.75	
GROUP 6.....	\$ 34.65	29.75	
GROUP 7.....	\$ 28.65	29.75	
GROUP 8.....	\$ 34.20	29.75	
GROUP 9.....	\$ 34.28	29.75	
GROUP 1.....	\$ 43.20	29.70	GROUP 1A.....\$
41.20	29.70		
GROUP 2.....	\$ 35.90	29.70	
GROUP 3.....	\$ 22.50	29.70	
GROUP 4.....	\$ 36.48	29.70	
GROUP 5.....	\$ 40.18	29.70	
GROUP 6.....	\$ 40.18	29.70	
GROUP 7.....	\$ 35.45	29.70	
GROUP 9.....	\$ 40.18	29.70	

a. FOOTNOTE: a. Any employee who works three days in the week in which a holiday falls shall be paid for the holiday.

a. PAID HOLIDAYS: New Year's Day, President's Day, Memorial Day, July Fourth, Victory Day, Labor Day, Columbus Day, Veterans Day, Thanksgiving Day & Christmas Day.

#### POWER EQUIPMENT OPERATOR CLASSIFICATIONS

GROUP 1: Crane, piledriver, lighter, boom truck, hoists, derrick

GROUP 1A: Digging machine, locomotive, John Henry's, directional drilling machine, cold planer, reclaimer, paver, spreader, grader, front end loader (3 yds. and over), vacuum truck, test boring machine operator, veemere saw, water blaster, hydro-demolition robot, forklift, economobile, Ross Carrier, concrete pump operator and boats

GROUP 2: Well point installation crew

GROUP 3: Utility engineers and signal persons

GROUP 4: Oiler on cranes

GROUP 5: Combination loader backhoe, front end loader (less than 3 yds.), forklift, bulldozers & scrapers and boats

GROUP 6: Roller, skid steer loaders, street sweeper

GROUP 7: Gas and electric drive heater, concrete mixer, light plant, welding machine, pump & compressor

GROUP 8: Stone crusher

GROUP 9: Mechanic & welder

003 06/01/2024

BUILDING CONSTRUCTION

Rates Fringes

Power Equipment Operator

GROUP 1.....	\$ 47.32	29.90	
GROUP 2.....	\$ 45.32	29.90	GROUP 3.....\$ 45.10
29.90			
GROUP 4.....	\$ 41.10	29.90	
GROUP 5.....	\$ 37.50	29.90	
GROUP 6.....	\$ 38.25	29.90	
GROUP 7.....	\$ 43.97	29.90	
GROUP 8.....	\$ 41.29	29.90	

a. BOOM LENGTHS, INCLUDING JIBS:

- 150 ft. and over: + \$ 2.00
- 180 ft. and over: + \$ 3.00
- 210 ft. and over: + \$ 4.00
- 240 ft. and over: + \$ 5.00
- 270 ft. and over: + \$ 7.00
- 300 ft. and over: + \$ 8.00
- 350 ft. and over: + \$ 9.00
- 400 ft. and over: + \$10.00

a. PAID HOLIDAYS: New Year's Day, President's Day, Memorial Day, July Fourth, Victory Day, Labor Day, Columbus Day, Veterans Day, Thanksgiving Day & Christmas Day. a: Any employee who works 3 days in the week in which a holiday

falls shall be paid for the holiday.

a. FOOTNOTE: Hazmat work: \$2.00 per hour additional. Tunnel/Shaft work: \$5.00 per hour additional.

POWER EQUIPMENT OPERATORS CLASSIFICATIONS

GROUP 1: Cranes, lighters, boom trucks and derricks.

GROUP 2: Digging machine, Ross carrier, locomotive, hoist, elevator, bidwell-type machine, shot & water blasting machine, paver, spreader, front end loader (3 yds. and over), vibratory hammer and vacuum truck

GROUP 3: Telehandler equipment, forklift, concrete pump & on-site concrete plant

GROUP 4: Fireman & oiler on cranes

GROUP 5: Oiler on crawler backhoe

GROUP 6: Bulldozer, skid steer loaders, bobcats, tractor, grader,

scraper, combination loader backhoe, roller, front end loader (less than 3 yds.), street and mobile powered sweeper (3 yds. capacity), 8-ft. sweeper (minimum 65 hp)

GROUP 7: Well point installation crew

GROUP 8: Heater, concrete mixer, stone crusher, welding machine, generator for light plant, gas and electric driven pump & air compressor

----- \* IRON0037-  
001 03/16/2024  
Rates Fringes

IRONWORKER.....\$ 40.75 32.83 -----  
----- LABO0271-001 12/03/2023

BUILDING CONSTRUCTION

Rates Fringes

LABORER

GROUP 1.....\$ 37.00 26.90  
GROUP 2.....\$ 37.00 26.90  
GROUP 3.....\$ 37.00 26.90  
GROUP 4.....\$ 37.00 26.90  
GROUP 5.....\$ 39.00 26.90 LABORERS CLASSIFICATIONS

GROUP 1: Laborer, Carpenter Tender, Mason Tender, Cement Finisher Tender, Scaffold Erector, Wrecking Laborer, Asbestos Removal [Non-Mechanical Systems]

GROUP 2: Asphalt Raker, Adzemen, Pipe Trench Bracer, Demolition Burner, Chain Saw Operator, Fence & Guard Rail Erector, Setter of Metal Forms for Roadways, Mortar Mixer, Pipelayer, Riprap & Dry Stonewall Builder, Highway Stone Spreader, Pneumatic Tool Operator, Wagon Drill Operator, Tree Trimmer, Barco-Type Jumping Tamper, Mechanical Grinder Operator

GROUP 3: Pre-Cast Floor & Roof Plank Erectors

GROUP 4: Air Track Operator, Hydraulic & Similar Self-Powered Drill, Block Paver, Rammer, Curb Setter, Powderman & Blaster

GROUP 5: Toxic Waste Remover

LABORERS CLASSIFICATIONS

GROUP 1: Laborer, Carpenter Tender, Mason Tender, Cement Finisher Tender, Scaffold Erector, Wrecking Laborer, Asbestos Removal [Non-Mechanical Systems]

GROUP 2: Asphalt Raker, Adzemen, Pipe Trench Bracer, Demolition Burner, Chain Saw Operator, Fence & Guard Rail Erector, Setter of Metal Forms for Roadways, Mortar Mixer, Pipelayer, Riprap & Dry Stonewall Builder, Highway Stone Spreader, Pneumatic Tool Operator, Wagon Drill Operator,

Tree Trimmer, Barco-Type Jumping Tamper, Mechanical Grinder Operator

GROUP 3: Pre-Cast Floor & Roof Plank Erectors

GROUP 4: Air Track Operator, Hydraulic & Similar Self-Powered Drill, Block Paver, Rammer, Curb Setter, Powderman & Blaster

GROUP 5: Toxic Waste Remover

----- LABO0271-  
002 11/27/2022

HEAVY AND HIGHWAY CONSTRUCTION

Rates Fringes

LABORER

COMPRESSED AIR

Group 1.....	\$ 55.40	24.15
Group 2.....	\$ 52.93	24.15
Group 3.....	\$ 42.45	24.15

FREE AIR

Group 1.....	\$ 46.00	24.15
Group 2.....	\$ 45.00	24.15
Group 3.....	\$ 42.45	24.15

LABORER

Group 1.....	\$ 33.05	24.05
Group 2.....	\$ 35.75	24.85
Group 3.....	\$ 36.50	24.85
Group 4.....	\$ 29.00	24.85
Group 5.....	\$ 37.50	24.85

OPEN AIR CAISSON,

UNDERPINNING WORK AND BORING CREW

Bottom Man.....	\$ 41.50	24.15
Top Man & Laborer.....	\$ 35.60	24.15

TEST BORING

Driller.....	\$ 41.95	24.15	Laborer.....	\$ 41.95
--------------	----------	-------	--------------	----------

24.15 LABORER CLASSIFICATIONS

GROUP 1: Laborer; Carpenter tender; Cement finisher tender; Wrecking laborer; Asbestos removers [non-mechanical systems]; Plant laborer; Driller in quarries

GROUP 2: Adzeperson; Asphalt raker; Barcotype jumping tamper; Chain saw operators; Concrete and power buggy operator; Concrete saw operator; Demolition burner; Fence and guard rail erector; Highway stone spreader; Laser beam operator; Mechanical grinder operator; Mason tender; Mortar mixer; Pneumatic tool operator; Riprap and dry stonewall builder; Scaffold erector; Setter of metal forms for roadways; Wagon drill operator; Wood chipper operator; Pipelayer; Pipe trench bracer

GROUP 3: Air track drill operator; Hydraulic and similar powered drills; Brick paver; Block paver; Rammer and curb setter; Powderperson and blaster

GROUP 4: Flagger & signaler

GROUP 5: Toxic waste remover

LABORER - COMPRESSED AIR CLASSIFICATIONS

GROUP 1: Mucking machine operator, tunnel laborer, brake person, track person, miner, grout person, lock tender, gauge tender, miner: motor person & all others in compressed air

GROUP 2: Change house attendant, powder watchperson, top person on iron

GROUP 3: Hazardous waste work within the "HOT" zone

LABORER - FREE AIR CLASSIFICATIONS

GROUP 1: Grout person - pumps, brake person, track person, form mover & stripper (wood & steel), shaft laborer, laborer topside, outside motorperson, miner, conveyor operator, miner welder, heading motorperson, erecting operator, mucking machine operator, nozzle person, rodperson, safety miner, shaft & tunnel, steel & rodperson, mole nipper, concrete worker, form erector (wood, steel and all accessories), cement finisher (this type of work only), top signal person, bottom person (when heading is 50' from shaft), burner, shield operator and TBM operator

GROUP 2: Change house attendant, powder watchperson

GROUP 3: Hazardous waste work within the "HOT" zone

LABORER CLASSIFICATIONS

GROUP 1: Laborer; Carpenter tender; Cement finisher tender; Wrecking laborer; Asbestos removers [non-mechanical systems]; Plant laborer; Driller in quarries

GROUP 2: Adzeperson; Asphalt raker; Barcotype jumping tamper; Chain saw operators; Concrete and power buggy operator; Concrete saw operator; Demolition burner; Fence and guard rail erector; Highway stone spreader; Laser beam operator; Mechanical grinder operator; Mason tender; Mortar mixer; Pneumatic tool operator; Riprap and dry stonewall builder; Scaffold erector; Setter of metal forms for roadways; Wagon drill operator; Wood chipper operator; Pipelayer; Pipe trench bracer

GROUP 3: Air track drill operator; Hydraulic and similar powered drills; Brick paver; Block paver; Rammer and curb setter; Powderperson and blaster

GROUP 4: Flagger & signaler

GROUP 5: Toxic waste remover

LABORER - COMPRESSED AIR CLASSIFICATIONS

GROUP 1: Mucking machine operator, tunnel laborer, brake person, track person, miner, grout person, lock tender,

gauge tender, miner: motor person & all others in compressed air

GROUP 2: Change house attendant, powder watchperson, top person on iron

GROUP 3: Hazardous waste work within the "HOT" zone

LABORER - FREE AIR CLASSIFICATIONS

GROUP 1: Grout person - pumps, brake person, track person, form mover & stripper (wood & steel), shaft laborer, laborer topside, outside motorperson, miner, conveyor operator, miner welder, heading motorperson, erecting operator, mucking machine operator, nozzle person, rodperson, safety miner, shaft & tunnel, steel & rodperson, mole nipper, concrete worker, form erector (wood, steel and all accessories), cement finisher (this type of work only), top signal person, bottom person (when heading is 50' from shaft), burner, shield operator and TBM operator

GROUP 2: Change house attendant, powder watchperson

GROUP 3: Hazardous waste work within the "HOT" zone

----- \* PAIN0011-005 06/01/2024

Rates Fringes

PAINTER

Brush and Roller.....\$ 38.07 25.80  
Epoxy, Tanks, Towers,  
Swing Stage & Structural  
Steel.....\$ 40.07 25.80  
Spray, Sand & Water  
Blasting.....\$ 41.07 25.80 Taper.....\$  
38.82 25.80  
Wall Coverer.....\$ 38.57 25.80 -----

----- PAIN0011-006 06/01/2022

Rates Fringes

GLAZIER.....\$ 40.78 23.40

FOOTNOTES:

SWING STAGE: \$1.00 per hour additional.

PAID HOLIDAYS: Labor Day & Christmas Day.

----- PAIN0011-011 06/01/2023

Rates Fringes

Painter (Bridge Work).....\$ 56.25 23.45 -----  
----- PAIN0035-008 06/01/2011

Rates Fringes

Sign Painter.....\$ 24.79 13.72 -----  
----- PLAS0040-001 01/01/2024

BUILDING CONSTRUCTION

Rates Fringes

CEMENT MASON/CONCRETE FINISHER...\$ 43.00 29.10

FOOTNOTE: Cement Mason: Work on free swinging scaffolds under 3 planks width and which is 20 or more feet above ground and any offset structure: \$.30 per hour additional.

----- PLAS0040-  
002 01/01/2024

HEAVY AND HIGHWAY CONSTRUCTION

Rates Fringes

CEMENT MASON/CONCRETE FINISHER...\$ 38.45 25.30 -----  
----- PLAS0040-003 01/01/2024

Rates Fringes

PLASTERER.....\$ 43.65 29.43 -----  
----- PLUM0051-002 08/28/2023

Rates Fringes

Plumbers and Pipefitters.....\$ 50.59 32.75 -----  
----- \* ROOF0033-004 06/01/2024

Rates Fringes

ROOFER.....\$ 44.80 31.13 -----  
----- SFRI0669-001 04/01/2024

Rates Fringes

SPRINKLER FITTER.....\$ 49.98 32.85 -----  
----- \* SHEE0017-002 06/01/2024

Rates Fringes

Sheet Metal Worker.....\$ 42.69 38.45 -----  
----- TEAM0251-001 05/01/2024

HEAVY AND HIGHWAY CONSTRUCTION

Rates Fringes

TRUCK DRIVER

GROUP 1.....	\$ 30.71	36.9125+A+B	
GROUP 2.....	\$ 30.86	36.9125+A+B	
GROUP 3.....	\$ 30.91	36.9125+A+B	
GROUP 4.....	\$ 30.96	36.9125+A+B	
GROUP 5.....	\$ 31.06	36.9125+A+B	
GROUP 6.....	\$ 31.46	36.9125+A+B	
GROUP 7.....	\$ 31.66	36.9125+A+B	
GROUP 8.....	\$ 31.16	36.9125+A+B	GROUP 9.....\$
31.41		36.9125+A+B	
GROUP 10.....	\$ 31.21	36.9125+A+B	

FOOTNOTES:

A. Paid Holidays: New Year's Day, Memorial Day, Independence Day, Labor Day, Thanksgiving Day and Christmas Day, plus Presidents' Day, Columbus Day, Veteran's Day & V-J Day, providing the employee has worked at least one day in the calendar week in which the holiday falls.

B. Employee who has been on the payroll for 1 year or more but less than 5 years and has worked 150 Days during the last year of employment shall receive 1 week's paid vacation; 5 to 10 years - 2 weeks' paid vacation; 10 or more years - 3 week's paid vacation.

C. Employees on the seniority list shall be paid a one hundred dollar (\$100.00) bonus for every four hundred (400) hours worked, up to a maximum of five hundred dollars (\$500.00)

All drivers working on a defined hazard material job site shall be paid a premium of \$2.00 per hour over applicable rate.

TRUCK DRIVER CLASSIFICATIONS

GROUP 1: Pick-up trucks, station wagons, & panel trucks

GROUP 2: Two-axle on low beds

GROUP 3: Two-axle dump truck

GROUP 4: Three-axle dump truck

GROUP 5: Four- and five-axle equipment

GROUP 6: Low-bed or boom trailer.

GROUP 7: Trailers when used on a double hook up (pulling 2 trailers)

GROUP 8: Special earth-moving equipment, under 35 tons

GROUP 9: Special earth-moving equipment, 35 tons or over



GROUP 10: Tractor trailer

-----  
WELDERS - Receive rate prescribed for craft performing operation to which welding is incidental.

=====  
Note: Executive Order (EO) 13706, Establishing Paid Sick Leave for Federal Contractors applies to all contracts subject to the Davis-Bacon Act for which the contract is awarded (and any solicitation was issued) on or after January 1, 2017. If this contract is covered by the EO, the contractor must provide employees with 1 hour of paid sick leave for every 30 hours they work, up to 56 hours of paid sick leave each year. Employees must be permitted to use paid sick leave for their own illness, injury or other health-related needs, including preventive care; to assist a family member (or person who is like family to the employee) who is ill, injured, or has other health-related needs, including preventive care; or for reasons resulting from, or to assist a family member (or person who is like family to the employee) who is a victim of, domestic violence, sexual assault, or stalking. Additional information on contractor requirements and worker protections under the EO is available at <https://www.dol.gov/agencies/whd/government-contracts>.

Unlisted classifications needed for work not included within the scope of the classifications listed may be added after award only as provided in the labor standards contract clauses (29CFR 5.5 (a) (1) (iii)).

-----  
The body of each wage determination lists the classification and wage rates that have been found to be prevailing for the cited type(s) of construction in the area covered by the wage determination. The classifications are listed in alphabetical order of "identifiers" that indicate whether the particular rate is a union rate (current union negotiated rate for local), a survey rate (weighted average rate) or a union average rate (weighted union average rate).

Union Rate Identifiers

A four letter classification abbreviation identifier enclosed in dotted lines beginning with characters other than "SU" or "UAVG" denotes that the union classification and rate were prevailing for that classification in the survey. Example: PLUM0198-005 07/01/2014. PLUM is an abbreviation identifier of the union which prevailed in the survey for this classification, which in this example would be Plumbers. 0198 indicates the local union number or district council number where applicable, i.e., Plumbers Local 0198. The next number, 005 in the example, is an internal number used in processing the wage determination. 07/01/2014 is the effective date of the most current

negotiated rate, which in this example is July 1, 2014.

Union prevailing wage rates are updated to reflect all rate changes in the collective bargaining agreement (CBA) governing this classification and rate.

#### Survey Rate Identifiers

Classifications listed under the "SU" identifier indicate that no one rate prevailed for this classification in the survey and the published rate is derived by computing a weighted average rate based on all the rates reported in the survey for that classification. As this weighted average rate includes all rates reported in the survey, it may include both union and non-union rates. Example: SULA2012-007 5/13/2014. SU indicates the rates are survey rates based on a weighted average calculation of rates and are not majority rates. LA indicates the State of Louisiana. 2012 is the year of survey on which these classifications and rates are based. The next number, 007 in the example, is an internal number used in producing the wage determination. 5/13/2014 indicates the survey completion date for the classifications and rates under that identifier.

Survey wage rates are not updated and remain in effect until a new survey is conducted.

#### Union Average Rate Identifiers

Classification(s) listed under the UAVG identifier indicate that no single majority rate prevailed for those classifications; however, 100% of the data reported for the classifications was union data. EXAMPLE: UAVG-OH-0010 08/29/2014. UAVG indicates that the rate is a weighted union average rate. OH indicates the state. The next number, 0010 in the example, is an internal number used in producing the wage determination. 08/29/2014 indicates the survey completion date for the classifications and rates under that identifier.

A UAVG rate will be updated once a year, usually in January of each year, to reflect a weighted average of the current negotiated/CBA rate of the union locals from which the rate is based.

#### State Adopted Rate Identifiers

Classifications listed under the "SA" identifier indicate that the prevailing wage rate set by a state (or local) government was adopted under 29 C.F.R '1.3(g)-(h). Example: SAME2023-007 01/03/2024. SA reflects that the rates are state adopted. ME refers to the State of Maine. 2023 is the year during which the state completed the survey on which the listed classifications and rates are based. The next number, 007 in the example, is an internal number used in producing the wage determination. 01/03/2024 reflects the date on which the classifications and rates under the ?SA? identifier took effect under state law in the state from which the rates were adopted.

- 1.) Has there been an initial decision in the matter? This can be:
- \* an existing published wage determination
  - \* a survey underlying a wage determination
  - \* a Wage and Hour Division letter setting forth a position on a wage determination matter
  - \* a conformance (additional classification and rate) ruling

On survey related matters, initial contact, including requests for summaries of surveys, should be with the Wage and Hour National Office because National Office has responsibility for the Davis-Bacon survey program. If the response from this initial contact is not satisfactory, then the process described in 2.) and 3.) should be followed.

With regard to any other matter not yet ripe for the formal process described here, initial contact should be with the Branch of Construction Wage Determinations. Write to:

Branch of Construction Wage Determinations  
Wage and Hour Division  
U.S. Department of Labor  
200 Constitution Avenue, N.W.  
Washington, DC 20210

- 2.) If the answer to the question in 1.) is yes, then an interested party (those affected by the action) can request review and reconsideration from the Wage and Hour Administrator (See 29 CFR Part 1.8 and 29 CFR Part 7). Write to:

Wage and Hour Administrator  
U.S. Department of Labor  
200 Constitution Avenue, N.W.  
Washington, DC 20210

The request should be accompanied by a full statement of the interested party's position and by any information (wage payment data, project description, area practice material, etc.) that the requestor considers relevant to the issue.

- 3.) If the decision of the Administrator is not favorable, an interested party may appeal directly to the Administrative Review Board (formerly the Wage Appeals Board). Write to:

Administrative Review Board  
U.S. Department of Labor  
200 Constitution Avenue, N.W.  
Washington, DC 20210

- 4.) All decisions by the Administrative Review Board are final.

=====

END OF GENERAL DECISION"

**Addendum No. 2**  
**Attachment 2 – Revised Drawing Sheet C-6**

**GRANITE CURB**

1/2" CHAMFER  
CHAMFER 1/2"  
3'-0" MIN.  
1'-6"  
6" ± 1"  
QUARRY SPLIT  
CIRCULAR CURB  
R=160'-0" MIN.  
1/2" CHAMFER

NOTES:  
1. SHALL BE IN ACCORDANCE WITH SECTION 906 OF THE R.I. STANDARD SPECIFICATIONS.  
2. TOP SURFACE TO BE DRESSED BY SAW. REMAINDER MAY BE QUARRY SPLIT.  
3. MINIMUM LENGTH OF STRAIGHT OR CIRCULAR PIECES TO BE 3'-0".  
4. CIRCULAR CURB IS REQUIRED ON CURVES WITH RADI OF 160'-0" OR LESS. STRAIGHT CURB TO BE USED ON CURVES OF MORE THAN 160'-0" RADIUS.

RHODE ISLAND DEPARTMENT OF TRANSPORTATION  
NO. BY DATE GRANITE CURB R.I. STANDARD 7.3.0  
1. M.P. 10/2005  
2. M.P. 10/2012  
JUNE 15, 1998  
DERICK HOPKINS  
REGISTERED PROFESSIONAL ENGINEER  
CIVIL

**STEEL BACKED TIMBER GUARDRAIL**

STEEL RAIL DETAIL  
6"x3/8"x9'-9"

PLATE WASHER DETAIL  
3"x4"x1/2"

POST CONNECTION PLAN

STEEL SPLICE PLATE DETAIL  
6"x3/8"x12'-8"

POST CONNECTION ELEVATION

SECTION A-A

NOTES:  
1. SHALL BE IN ACCORDANCE WITH SECTION 902 OF THE R.I. STANDARD SPECIFICATIONS.  
2. ALL STRUCTURAL STEEL AND FASTENER HARDWARE SHALL BE WEATHERING STEEL AS SPECIFIED.

RHODE ISLAND DEPARTMENT OF TRANSPORTATION  
NO. BY DATE STEEL BACKED TIMBER GUARDRAIL R.I. STANDARD 4.4.0  
1. M.P. 10/2005  
2. M.P. 10/2012  
JUNE 15, 1998  
DERICK HOPKINS  
REGISTERED PROFESSIONAL ENGINEER  
CIVIL

**6'-0" PRECAST CONCRETE TRANSITION CURB**

6'-0"  
10"  
6"  
1 1/2"  
6 1/2"  
9"  
2 1/4"  
3 1/2"  
1 1/2"  
3/4"  
5/8" x 2 1/4" DOWEL SOCKET (SEE NOTE 2)

GUTTER LINE

NOTES:  
1. SHALL BE IN ACCORDANCE WITH SECTION 906 OF THE R.I. STANDARD SPECIFICATIONS.  
2. DRAWING SHOWS TRANSITION CURB FOR ONE DIRECTION FOR OTHER DIRECTION USE OPPOSITE HAND AND INCLUDE A 1/2" x 4" EPOXY COATED DOWEL.  
3. EXPOSED SURFACES TO HAVE A SPONGE FLOAT FINISH.  
4. EXPOSED EDGES TO HAVE A 3/4" CHAMFER.

RHODE ISLAND DEPARTMENT OF TRANSPORTATION  
NO. BY DATE 6'-0" PRECAST CONCRETE TRANSITION CURB R.I. STANDARD 7.1.2  
1. M.P. 10/2005  
2. M.P. 10/2012  
JUNE 15, 1998  
DERICK HOPKINS  
REGISTERED PROFESSIONAL ENGINEER  
CIVIL

**CURB SETTING DETAIL**

NEW BITUMINOUS CONCRETE PAVEMENT  
NEW SIDEWALK OR GRASSED AREA  
CURB  
GRAVEL BORROW SUBBASE  
CEMENT CONCRETE (SEE NOTE 2)

NOTES:  
1. SHALL BE IN ACCORDANCE WITH SECTION 906 OF THE R.I. STANDARD SPECIFICATIONS.  
2. CEMENT CONCRETE SHALL BE USED ONLY WHEN THE CURB IS SET AFTER THE BASE AND/OR BINDER COURSES ARE IN PLACE, OTHERWISE THE CEMENT CONCRETE WILL BE ELIMINATED AND THE GRAVEL BROUGHT UP TO BOTTOM OF THE BASE COURSE.

RHODE ISLAND DEPARTMENT OF TRANSPORTATION  
NO. BY DATE CURB SETTING DETAIL R.I. STANDARD 7.6.0  
1. M.P. 10/2005  
2. M.P. 10/2012  
JUNE 15, 1998  
DERICK HOPKINS  
REGISTERED PROFESSIONAL ENGINEER  
CIVIL

**SQUARE FRAME AND GRATE (BICYCLE SAFE)**

2'-9 1/4"  
3 3/4"  
4th FLANGE WHEN ORDERED  
FLOW DIRECTION  
NOTE: FRAME AND GRATE SHALL CONFORM TO SECTION M.04 OF THE R.I. STANDARD SPECIFICATIONS.

SECTION A-A  
SECTION B-B  
SECTION C-C

NOTES:  
1. SHALL BE IN ACCORDANCE WITH SECTION 906 OF THE R.I. STANDARD SPECIFICATIONS.  
2. CEMENT CONCRETE SHALL BE USED ONLY WHEN THE CURB IS SET AFTER THE BASE AND/OR BINDER COURSES ARE IN PLACE, OTHERWISE THE CEMENT CONCRETE WILL BE ELIMINATED AND THE GRAVEL BROUGHT UP TO BOTTOM OF THE BASE COURSE.

RHODE ISLAND DEPARTMENT OF TRANSPORTATION  
NO. BY DATE SQUARE FRAME AND GRATE (BICYCLE SAFE) R.I. STANDARD 6.3.2  
1. M.P. 7/27/06  
2. M.P. 10/2012  
JUNE 15, 1998  
DERICK HOPKINS  
REGISTERED PROFESSIONAL ENGINEER  
CIVIL

NO.	DATE	DESCRIPTION
1		ADDITION OF CITY STANDARD BENCH DETAIL

DESIGNED BY: D. HOPKINS  
CAD COORD.: J. MICHAUD  
CHECKED BY:  
DATE:  
APPROVED BY:  
DATE:  
PROJECT NO.: 13981

**PRECAST CONCRETE DROP INLET**

PLAN  
SECTION A-A  
SECTION B-B

CONCRETE TOLERANCES  
DIMENSION TOLERANCE  
0'-12" 1/4"  
12'-24" 1/2"  
24'-36" 3/4"

NOTES:  
1. SHALL BE IN ACCORDANCE WITH SECTION 702 OF THE R.I. STANDARD SPECIFICATIONS.  
2. MINIMUM REQUIRED CONCRETE REINFORCEMENT = 0.12 SQ. IN./LIN. FT. (EACH WAY).  
3. MINIMUM COVER ON REINFORCEMENT SHALL BE 2".

RHODE ISLAND DEPARTMENT OF TRANSPORTATION  
NO. BY DATE PRECAST CONCRETE DROP INLET R.I. STANDARD 4.5.0  
1. M.P. 10/2005  
2. M.P. 10/2012  
JUNE 15, 1998  
DERICK HOPKINS  
REGISTERED PROFESSIONAL ENGINEER  
CIVIL

### CITY STANDARD BENCH

SCALE: NTS

**LENGTH OPTIONS**  
 6' BENCH  
 8' BENCH

**SLAT OPTIONS**  
 "CEDAR" RECYCLED PLASTIC  
 "GREY" RECYCLED PLASTIC  
 "REDWOOD" RECYCLED PLASTIC  
 "WALNUT" RECYCLED PLASTIC  
 OTHER

NOTES:  
1) ALL ALUM. & STL. MEMBERS COATED W/ ZINC RICH EPOXY THEN FINISHED W/ POLYESTER POWDER COATING.  
2) 1/2" X 3 3/4" EXPANSION ANCHOR BOLT PROVIDED.

**TOOLS REQ'D**  
3/4" WRENCH  
9/16" WRENCH  
1/4" ALLEN WRENCH  
5/16" ALLEN WRENCH  
1/2" MASONRY DRILL BIT  
DRILL  
RATCHET STRAP (PROVIDED)

**ASSEMBLY INSTRUCTIONS**

REMOVE 1/2" X 2" HEX HEAD BOLT AND SHIPPING BRACE AND DISCARD  
DETACH LOWER PIPE, ATTACH FIRST 3 SLATS, RE-ATTACH LOWER PIPE  
SLAT LAYOUT

ITEM	QTY	PART NO.	DESCRIPTION
1	6	0-143-60PL-01	2" X 3" X 71" INT'L SLAT, PLASTIC
2	2	0-143-60PL-02	2" X 3" X 71" PLASTIC EDGE SLAT
3	4	0-165-60PL-03	71" TRAP SLAT, PLASTIC
4	2	0-165-60PL-32	2" X 3" X 71" SLAT, FOR CENTER ARM, PLASTIC
5	2	0-446-00-01	CAST ALUM. SUPPORT
6	1	0-447-00AR-0A	ALUM. ARMREST
7	1	0-447-00	6" STL. SEAT FRAME ASSEMBLY
8	1	0-443-60PL-03	71" TRAP SLAT, PLASTIC
9	2	1-11-044	1/2" X 3" SS COE. BOX
10	4	1-12-085	1/2" X 2 1/2" FLT. SKT. HD. CAP SCR.
11	60	1-13-023	5/16" X 1 1/4" SS BHN. SKT. HD. LAG
12	2	1-20-015	1/2" SS WELON LOCKOUT
13	2	1-22-015	1/2" SS FLAT WASHER
14	60	1-22-017	5/16" SS FLAT WASHER

DATE DRAWN: 08/26/13  
DRAWN BY: ESS  
DATE REV.: 00/00/00  
REV. BY: XXX

REV. A DRAWING NUMBER 447 SERIES PL-3AR SHEET 1 OF 2

DATE DRAWN: 09/20/18  
DRAWN BY: ESS  
DATE REV.: 00/00/00  
REV. BY: XXX

REV. A DRAWING NUMBER 447 SERIES PL-3AR SHEET 2 OF 2

**WRIGHT-PIERCE**  
Engineering a Better Environment  
888.621.8156 | www.wright-pierce.com

CITY OF EAST PROVIDENCE, RHODE ISLAND  
BOOTH AVENUE SLOPE STABILIZATION

DRAWING  
C-6