



**CITY OF EAST PROVIDENCE
DEPARTMENT OF PUBLIC WORKS
RFP EP23/24-06
REMOVAL & REPLACEMENT OF HVAC SYSTEM AT FULLER CREATIVE LEARNING
CENTER**

Addendum #2

Please be advised that the following information comprises Addendum #2.

The following question was submitted by a perspective vendor:

Does the existing fire alarm system have a duct smoke detector installed and tied into the fire alarm panel?

Answer: No, there is no duct smoke detector installed and tied in to the existing system. This should be included in the vendor's submission for the new system.

The bid opening will be held on Tuesday, February 13, 2024 at 11:00am in Conference Room 306 at East Providence City Hall.

Any questions should be directed to Andrew Baum, HVAC Technician at abaum@eastprovidenceri.gov or Jessica Lamprey, Procurement Specialist at jlamprey@eastprovidenceri.gov no later than **MONDAY, FEBRUARY 5, 2024 BY 4:00PM.**

Equal Opportunity/Affirmative Action Employer

Jessica Lamprey, Procurement Specialist
jlamprey@eastprovidenceri.gov