



**CITY OF EAST PROVIDENCE
WATER MAIN CLEANING AND LINING PHASE V REBID
RFP EP23/24-26R**

ADDENDUM # 3 – OCTOBER 16, 2024

BID OPENING THURSDAY OCTOBER 24, 2024 AT 2:00 PM

The following revisions, clarifications, additions and/or deletions are hereby made a part of the Bid Documents for the City of East Providence's Water Main Cleaning and Lining Phase V Rebid project, RFP EP23/24-26R.

Drawings:

1. Drawing C1.0 (Sheet 2 of 26), **DELETE** Note 1 under Specifications of Water Main, Valves, and Appurtenances in its entirety and **REPLACE** with:

“1. GENERAL: ALL MATERIALS SHALL BE NEW, UNUSED, AND PURCHASED SPECIFICALLY FOR THIS PROJECT. ALL WATER MAIN, VALVES, AND APPURTENANCES SHALL BE MADE IN THE UNITED STATES OF AMERICA AND SHALL BE PROVIDED WITH DOCUMENTATION INDICATING THE LOCATION OF FOUNDRY AND/OR PLACE OF ORIGIN. ALL MATERIALS SHALL COMPLY WITH AMERICAN IRON AND STEEL (AIS) REQUIREMENTS AND BUILD AMERICA, BUY AMERICA (BABA) ACT REQUIREMENTS.”

Clarifications:

1. The City will accept type 304 stainless steel or fluoropolymer coated fitting accessories and hardware, such as Fluorokote #1 or approved equal.